



Monitoring Violations Annual Notice

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met

Our water system violated drinking water requirements over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we are doing (did) to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2021 we 'did not complete all monitoring or testing' for Synthetic organic contaminants and therefore cannot be sure of the quality of your drinking water during that time

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for *Synthetic organic contaminants*, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.¹

| Contaminant | Required sampling frequency | Number of samples taken | When samples should have been taken | When samples were taken |
|-------------|-----------------------------|-------------------------|-------------------------------------|-------------------------|
| SOCs | 1 sample every three years | 0 | 2021 | January 31, 2022 |

What is being done?

Upon notification of no sample for the year 2021, we immediately pulled a sample and sent to lab for testing. We are implementing a check and balance system to ensure "ALL" samples are taken.

For more information, please contact Brandon George at 863-832-2444 or brandon.george@inframark.com.

This notice is being sent to you by City of Bowling Green. State Water System ID#: 6252022.

Date distributed: January 31, 2022

¹VOCs, also known as volatile organic compounds, are tested by collecting one sample and testing that sample for all the regulated VOCs. VOCs are commonly used in industrial and manufacturing processes. Regulated VOCs include benzene, carbon tetrachloride, chlorobenzene, 1,2-dichlorobenzene, 1,4-dichlorobenzene, 1,2-dichloroethane, cis-dichloroethane, trans-dichloroethane, dichloromethane, 1,2-dichloropropane, ethylbenzene, styrene, tetrachloroethylene, 1,1,1-trichloroethane, trichloroethylene, toluene, 1,2,4-trichlorobenzene, 1,1-dichloroethylene, 1,1,2-trichloroethane, vinyl chloride, and xylene.